Orbis

Conventional Galvanic Barrier



Product Overview

Conventional Galvanic Barrier **Product**

29600-378 Part No.

Product Information

The Conventional Galvanic Barrier is DIN-Rail mounted and installed in the safe area to ensure system integrity.

The device also enables compliance with the ATEX directive

Technical data

All data is supplied subject to change without notice. Specifications are typical at 24 V, 23°C and 50% RH unless otherwise stated.

Inputs (Not intrinsically safe) Terminals 12-, 11+; 8-, 10-, 9+

Nominal voltage DC 4 V ... 35 V

Max. current consumption 0 mA ... 40 mA

Max. power dissipation

at 40 mA and U_E < 23.7 V < 700 mW per channel at 40 mA and $U_F > 23.7 \text{ V}$ < 1.2 W per channel

Fail-safe maximum voltage Um 250 V

Field circuit (Intrinsically Terminals 1+, 2-; 4+, 5safe)

Min. output voltage for $3 V < U_F < 23.7 V$ U_F - (0.4 x current in mA) - 0.7 for $U_E > 23.7 \text{ V}$ 23 V - (0.4 x current in mA)

Max. short-circuit current at

≤ 65 mA $U_F > 23.7 \text{ V}$

≤ 40 mA Max. transfer current

BASEEFA No. Ex-88.B.2331 Details of Certificate of Conformity Other international approvals

Technical data (cont'd)

Voltage U 28 V Current I 93 mA Power P 0.65 W

Permissible circuit values ignition protection class,

[EEx ia] category

Explosion group IIA IIB IIC

1.04 μF 0.39 μF 0.13 μF Max. external capacitance 33.6 mH 12.6 mH 4.2 mH Max. external inductance

Fail-safe maximum voltage Um

Power supply 250 V

Entity parameters FM No. 1Z2A1.AX

Terminals 1+, 2-; 4+, 5-

26.71 V Voltage Voc Current I_{sc} 88.8 mA

- V Voltage V.

Explosion group A&B C&E D, F&G Max. external capacitance $0.48 \mu F$ 1.28 µF $0.16 \, \mu F$ Max. external inductance 4.60 mH 18.32 mH 37.55 mH

CSA No. LR65756-13 Safety parameters Terminals 1+, 2-; 4+, 5-

KFD0-CS-Ex1.51

Voltage Voc 28.0 V 93.3 mA Current I_{sc}

A&B C&E D, F&G Explosion group Max. external capacitance 0.14 uF $0.42 \mu F$ $0.42 \mu F$ (C_a)

Max. external inductance (L_a) 3.1 mH

Transfer characteristics

 $\leq \pm 200 \,\mu\text{A}$ inclusive calibration, Calibrated accuracy at 20 °C linearity, hysteresis and load fluctuations (68 OF)

at the output up to 1 k0hm load

16.8 mH 16.8 mH

 $\leq 2~\mu\text{A}~/~\text{K}~(~273~\text{K}~...~323~\text{K}) \leq 5~\mu\text{A}~/~\text{K}~(253~\text{K}~...~333~\text{K})$ Temperature drift

Rise time ≤ 20 ms at 20 ms and 250 0hm load

Conformity to standard

to EN 50 178 Isolation co-ordination Galvanic isolation to EN 50 178 Climatical condition to IEC 721

to EN 50 081-2, EN 50 082-2, NAMUR NE 21 **EMC**

IP rating

Weight $\approx 100 g (\approx 3.5 oz)$

-20 °C ... +60 °C (-4 °F ... 140 °F) Ambient temperature

2.5 mm² (14 AWG) Max. wire size

36 Brookside Road, Havant Hampshire, PO9 1JR, UK.

Tel: +44 (0)23 9249 2412 | Fax: +44 (0)23 9249 2754

Email: sales@apollo-fire.com Web: www.apollo-fire.co.uk














Three bases wired with a common LED Note: the earth terminal in the base is provided for convenience where continuity of a cable sheath or similar is required. It is not necessary for the correct operation of the detector nor is it provided as a termination point for a safety earth. Control If screened cable is used screen continuity should be maintained and panel the screen should be earthed only at one point. The earthing point should preferably be close to the safety barrier. The system complies with the requirements of the CPD only if wired using screened cable. For details of cable connections see BS EN 60079-14, section 12.2.2. Safety barrier Screen (Functional Earth)

